



TM65

Mid-level Report

GEW5 + GAG5 + GSTS5: Glide Eutectic Well + Amb. Cupbd + Ambient Gantry (S.Help & A.Serve) + S.Steel Tray Slide 5-1Gn

Assessment Date 02/04/2026

Manufacturer CED Fabrications

Contact Email sales@cedlimited.com

Metrics

Embodied Carbon

1,629 kgCO2e

Embodied Carbon Footprint



Product Information

| | |
|--|---------|
| Capacity of equipment/size (kW; m3; litres; etc.) | N/A |
| Product weight (kg) | 176 kg |
| Material % breakdown for at least 95% of the product weight? (Y/N) | Y |
| Product service life (years) | 10 |
| If refrigerant based, type of refrigerant used and GWP | N/A |
| Refrigerant charge (kg) | N/A |
| Energy consumption of the factory* per unit of product | 205 kWh |
| Location of manufacture* | N/A |
| Product complexity category | 3 |

| Embodied carbon results (kg CO2e) — breakdown | |
|---|-----------------------|
| A1: Material extraction | 718 kgCO2e |
| A2: Transport | 140 kgCO2e |
| A3: Manufacturing | 221 kgCO2e |
| A4: Transport to site | 7 kgCO2e |
| A5: Construction | N/A |
| B1: Refrigerant leakage during use | 0 kgCO2e |
| B2: Maintenance (if information given by manufacturer) | N/A |
| B3: Repair | 73 kgCO2e |
| B4: Replacement | N/A |
| B5: Refurbishment | N/A |
| B6: Operational energy | N/A |
| B7: Operational water | N/A |
| C1: Refrigerant leakage when decommissioning | 0 kgCO2e |
| C2: Transport | 2 kgCO2e |
| C3: Waste processing | 55 kgCO2e |
| C4: Disposal | 0.87 kgCO2e |
| Embodied carbon results (kg CO2e) — without refrigerant leakage | |
| A1–C4 without buffer factor (excluding B1, C1) | 1218 kgCO2e |
| A1–C4 with buffer factor (excluding B1, C1) | 1584 kgCO2e |
| Embodied carbon result (kg CO2e) — refrigerant leakage only | |
| B1 (refrigerant leakage during use) + C1 (refrigerant leakage at end of life) | N/A |
| Embodied carbon result with 'mid-level' calculation method — total | |
| Result of 'mid-level' calculation method | 1,629 kgCO2e |
| Assumptions | |
| A1: Material carbon coefficient source | CIBSE TM65, Table 2.1 |
| B1: Refrigerant annual leakage rate (%) | N/A |
| C1: Refrigerant end of life recovery rate (%) | N/A |
| B3: Materials replaced as part of repair (%) | 22 |
| C4: Percentage of product going to landfill (%) | 55 |